

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

LISTING NO. 1450-1423:109 Page 1 of 1

CATEGORY: Expansion Joints

LISTEE: Balco/Metalines Inc., 2626 South Sheridan, Wichita, Kansas 67217  
Contact: Dan Hilburn (316) 945-9328

DESIGN: Model 2HRCA. 2-hour fire-rated floor expansion joints, up to 12" wide, for use on interior concrete floor slabs with aluminum plate covers. Refer to listee's data sheet for detailed product description, assembly components and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, hourly rating, and CSFM label.

APPROVAL: Listed as a 2-hour fire-rated firestop with aluminum finish covers for floor expansion joints to 12" maximum.

NOTE: Formerly 1450-1098:109



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy  
Program Manager**